

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1477:107 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Mircom Technologies Ltd, *25 Interchange Way, Vaughan, Ontario, Canada L4K 5W3
Contact: Mara Cherubin (888) 660-4655 FAX (888) 660-4113

DESIGN: Model RA-1000 remote multiplex annunciator panel. The main annunciator module provides indication for 32 zones. Each adder annunciator module provides indication for 48 additional zones. Unit includes main annunciator chassis RAM-1032 and adder annunciator chassis RAX-1048. Model RAX-LCD Liquid Crystal Annunicator, Model MGD-32 Master Graphic Driver chassis, Model MGDS-16/16 Main Display Annunicator Chassis and Model AGD-048 Adder graphic Driver chassis. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-29 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as annunciator panel for use with listee's separately listed compatible fire alarm control unit. Model RA-1000 is suitable for use with listed compatible Model FA-1000 (CSFM Listing No. 7165-1477:106) and FX-2000 (CSFM Listing No. (7165-1477:111) fire alarm control units. Model RAX-LCD is suitable for use with listed compatible Model FX-2000 fire alarm control unit (CSFM Listing No. (7165-1477:111).

*Rev. 11-04-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager